



Pro3000 Ground Fault Locator Operating Instructions

WARNING – Read and understand the instructions before operating this unit. Failure to do so could lead to injury or death.

The Armada Technologies Pro3000 ground fault locator designed to find wire or cable damage that results in an electrical path to ground. The Pro3000 works on the principle of earth gradient theory and is sometimes referred to as an earth gradient fault detector. The Pro3000 will pinpoint the exact location of a grounded cable fault. The Pro3000 is NOT a cable path locator.

The complete kit for the Pro3000 kit consists of the following;

- (1) Pro3000R Receiving Box.
- (1) Pro3000AF Receiving Frame
- (1) Pro3000T Dual Power Transmitter (with rechargeable battery)
- (1) ProGS Ground Stake
- (1) Battery Charger
- (1) Operating Manual

Please be sure that all items are included before operating the Pro3000.

How it Works – The Pro3000T transmits voltage charges in rhythmic succession. The charges are applied through the leads and into the connected cable where they travel to the fault. At the fault, a certain percentage of the electrical current leaks to ground. This amount is determined by the relative resistance of the fault and subsequent path to the ground stake versus the other available paths for the current, including the normal termination point of the cable.

The receiver and the frame are then inserted into the ground along the path of the wire. As the current flows to the ground stake, some of it travels through the frame. By needle kick, the receiver determines which side of the frame received the current first and therefore, which direction the fault lies. By relocating the frame, the user can zero in as to exactly where the fault lies.

Batteries - The Pro3000 transmitter uses a 12v gel cell rechargeable battery (included). There is also a 110v AC recharger for this battery. The battery comes disconnected in shipping. To connect the battery, remove the finger screws located on each side of the transmitter control panel. Inside the compartment, you will see the battery and 2 connecting terminals using spade clips. Carefully remove the rubberized terminal covers and connect the spade clipped wires to the battery. Replace the cover and tighten the screws.

To recharge the transmitter battery, connect the charger to the charging receptacle on the transmitter and then plug into a wall outlet. The battery level indicator on the transmitter face will indicate the amount of charge in the battery.

The receiver module that sits atop the frame requires (1) 9V battery. Remove the screws on each side of the receiver and remove the cover. Connect a 9v square battery to the battery boot tightly and replace the cover.

Operational Warnings – The Pro3000 transmits a high voltage charge. Do not turn the transmitter on until all hook-ups are complete. This means the alligator clip to the ground stake and the alligator clip to the wire. NEVER TURN ON THE UNIT WHEN ANYONE IS TOUCHING THE CABLE, GROUND STAKE, OR ANY PART OF THE TRANSMITTER. Disconnect the wire to be tested from any other service, components, or anything that might be affected by high voltage. Completely isolate the cable.

FAILURE to follow instructions could lead to injury or death.

Operation –

1. Disconnect cable to be tested at both ends. Be sure you are disconnected from power, components or anything else that will transmit electrical current.
2. Assemble the receiver by placing the receiver module on top of the receiver frame and secure and connect the module to the frame. The the frame probes (the metal spike like portion that gets inserted into the ground) is loose, simply hand tighten it in a clockwise direction.
3. Starting at either end of the cable and with the transmitter off. Connect the black alligator clip lead to the ground stake and shove the stake into the ground as deeply as possible. Connect the red alligator clip lead to the cable to be tested.
4. After being sure that no one is touching the stake, cable, or leads, turn the Pro3000 transmitter on by placing the rocker switch in the on position. The

transmitter will produce an audible beeping sound indicating the current is being transmitted. Do not handle any component, cable, or stake while the Pro3000 is operating.

5. Select low or high power as per your preference. High power will find small leakages while low power will concentrate on larger faults. If you want to find all faults regardless of size, use high. If you are looking for larger faults only, use low.
6. Turn the receiver on and place the frame probes in the ground parallel to approximately over the path of the cable. Be sure to insert them into the ground. As the transmitter pulses, you should see the analog needle of the Pro3000 kick in the direction of the fault.
7. Remove the frame probes from the ground and move it in the direction of the initial needle kick along the path of the cable. Reinsert the frame probes into the ground and repeat the process of observing the needle initial needle direction kick.
8. As you pass the fault, the needle kick direction will reverse. In other words, as you continue down the path of the cable and follow the needle kicks, the needle will reverse its initial direction of kick after you pass the fault. This indicates the fault is between the last 2 fram insertion points.
9. Continue to move the frame along the path in the direction of the initial kick, zeroing in on the location of the fault. When you are directly over the fault, the needle will cease to kick. Mark the spot for repair.
10. **BEFORE ATTEMPTING REPAIR, TURN OFF THE PRO3000 TRANSMITTER AND DISCONNECT IT FROM THE CABLE. NEVER TOUCH THE TRANSMITTER, TRANSMITTER LEADS, OR CABLE BEING USED WHILE THE TRANSMITTER IS ON OTHER THAN TO TURN IT OFF. DO NOT USE THE PRO3000 IN THE RAIN. FAILURE TO READ AND UNDERSTAND THESE WARNINGS COULD LEAD TO INJURY OR DEATH.**

Tips and Notes

1. If the cable contains many faults, this can be confusing. All faults will exhibit some needle kick proportional to the amount of current leaking there. If you are interested in fixing all, just zero in on the first, fix, and start again with the second. If you are looking for larger faults, turn the transmitter power to low setting.
2. Small faults may be indicated by weak kicks. This makes sense when you consider that the amount of current leaking is what you are sensing and small leaks produce small current.
3. It is not uncommon for the needle kicks to cease between the transmitter and the fault. That is normal. Continue on the path of the cable until the signal returns.
4. If you are next to the transmitter when using the receiver, it can kick toward the receiver. Simply move farther down the cable away from the transmitter to get the proper direction of kick.

5. If you cannot insert the frame probes into the ground due to concrete, asphalt, try using wet sponges. This will increase the conductivity of the frame. You can also extend the frame by wrapping a wire around one foot of the frame and connecting the other end of the wire to a screwdriver. This in effect increases the size of the frame and allows the blocking feature to be straddled.

Warranty – Armada Technologies warrants all products for 12 months from manufacturing defects from the date of retail purchase. Armada Technologies will repair or replace any component that is returned to Armada Technologies within 12 months of purchase and does not exhibit signs of abuse or misuse. It is Armada Technologies sole discretion to determine this condition. Armada Technologies also reserves the right to require a proof of purchase in order to determine date and validity of purchase.

Armada Technologies Equipment Inc.
10701 Whispering Waters
Caledonia, MI 49316 USA
1-616-536-2038
www.armadatech.com